



CONCORD TOWNSHIP FIRE DEPARTMENT

Station 340
7990 Dublin Road
Delaware Ohio 43015
614 981 9781

05/16/2024

Nick Stauffenger, P.E
Kimley-Horn
7965 N. High Street
Suite 200
Columbus, Ohio 43235

Nick,

In reference to the Farneman Property Preliminary Plans dated 04/15/2024 KHA project NO.19027300, Concord Township Fire has reviewed and approves the plans as written with the following conditions:

1. If a gate is added to the emergency access drive it will have to be a siren activated opener.
2. The HOA will be responsible for keeping the emergency access road clear of the debris and snow at all times per the Ohio Fire Code 503.4
3. No parking will be allowed on the emergency access road at any time.

If you have any further questions, please feel free to contact me.

Fire Safety Inspector

Jack Guyton