



General Notes:

1. All wood to be pressure treated.
2. All post supports to be set in concrete.
3. All fasteners to be galvanized screws and appropriate for exterior use.
4. All riser and tread dimensions to be consistent in the run of stair.
5. Railing height to be 34" above decking.
6. All stair treads to be 2x10, Risers to be 2x6, stair stringer to be 2x10
7. Main deck platform to be Min. 6" below house finish floor elevation.

The image above represents the acceptable method of construction for a step design to be located at the rear elevation of homes. This method complies with the guidelines as described in the protective covenants for the development.

EXHIBIT F-5
Rear Step Design Requirements